SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134 Tel. (708) 544-3260 • Toll Free (800) 783-LABS Fax (708) 544-8587 www.suburbanlabs.com

Workorder: 1909628

September 19, 2019

Bob Jakupi Butler School Dist. 53 2801 York Rd. Oak Brook, IL 60523

TEL: (630) 573-2887

FAX:

RE: Drinking Water Lead Analysis

Dear Bob Jakupi:

Suburban Laboratories, Inc. received 30 sample(s) on 9/10/2019 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Holly Stephenson Logistics Assistant

HollyS@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



Client ID: Butler School Dist. 53

Project Name: Drinking Water Lead Analysis

1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587 www.suburbanlabs.com

Report Date: September 19, 2019

Workorder: 1909628

Analyte: Lead Method: EPA 200.8 Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1909628-001A	Nurses Rm Sink Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-002A	Nurses Rm Sink Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-003A	Outside 300 Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-004A	Outside 300 Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-005A	Outside 305 Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-006A	Outside 305 Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-007A	Outside 308 Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-008A	Outside 308 Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-009A	Main Lobby Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-010A	Main Lobby Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-011A	Kitchen Hand Sink Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-012A	Kitchen Hand Sink Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-013A	Rm 102 Hand Sink Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-014A	Rm 102 Hand Sink Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-015A	100 Wing Girls Bathroom Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-016A	100 Wing Girls Bathroom Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-017A	Room 103 Hand Sink Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-018A	Room 103 Hand Sink Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-019A	Outside Rm 106 Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-020A	Outside Rm 106 Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-021A	200 Hall Water Fountain Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-022A	200 Hall Water Fountain Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-023A	Teachers Lounge Water Cooler Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-024A	Teachers Lounge Water Cooler Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-025A	Basement Slop Sink Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-026A	Basement Slop Sink Flush	2.02	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-027A	Basement Art #1 Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-028A	Basement Art #1 Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019
1909628-029A	Basement Art Sink #2 Draw	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	Page 26f8/2019

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587 www.suburbanlabs.com

Report Date: September 19, 2019

Workorder: 1909628

Client ID: Butler School Dist. 53

Project Name: Drinking Water Lead Analysis

Analyte: Lead Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1909628-030A	Basement Art Sink #2 Flush	ND	2.00	μg/L	9/9/19 23:30	9/10/2019	9/18/2019

Holly Stephenson

From: Bob Jakupi <bjakupi@butler53.com>
Sent: Tuesday, September 10, 2019 11:59

To: Holly Stephenson

Subject: Re: Missing Sample Information

Hi Holly,

Sorry about that but here is threst of the information:

25; Basement slop Sink 8:35A:M

26 Basement slop sink

27: Basement art sink #1 8:45 A:M

28; Basement art sink #1

29: Basement art sink #2 8:55A:M

30; Basement art sink #2

Thank you, Bob

On Tue, Sep 10, 2019 at 11:32 AM Holly Stephenson HollyS@suburbanlabs.com wrote:

Results addressed to:		Atta	
Buffer School Dist. 53 Blob Johnson	Lead or (terrical) Mighter (miles)	Mone	25
# Where? (in. Altoher sink)		When?	
10 autide em 106 water f	10 million		
" 200 Hell 11/6 1. +0	(draw)	2 15 (W) PW	26
2 co Hall watte fainte	Manj	8. 20 ED PH	
25 Tenches Courge Viste Co	where (Out)	8 25 @ PM	
28 9 8244	(Otto)	D 53 (M) PM	
27	(4 (B)ph	All PM	77
29	(43 w)	AM PM	20
30	(draw)	TON PM	
3)	Pahj	AAI PAI	
73	(Can)	Add my	
4	(dan)	AN PM	
	Wall	ALI PM	78
	(Onny)		80
are you returning the samples? FedEx UPS 115	(A+A)	ANI PM	0.0
SIGNATURE B. Otus &	SPS (Dropoff) Other.		
Paragrate!	TH SAMPLES		59
	WO PO PRES	·	
9.10	40 54	4.0	Manual 1
9.10.1	9 10:15-15	LAB FORM 2 OF 2	
	00	2	
			A 40.00
			0.0
			30

Hi, I received your samples today and noticed you did not completely fill out the lab form for all the samples. We are missing locations and times for samples 25-30. Please respond to this email with locations and times as soon as possible so I can enter your data into our system and get them to the lab. As of now, they will not be run until I have collection information. Thanks.



Holly Stephenson

Project Manager

(708) 544 - 3260 [X238]

Holly Stephenson

_

Bob Jakupi
Buildings and Grounds Director
Butler School District 53
2801 York Rd.
Oak Brook, II. 60523
Voice ~ 630/573-2887 Ext. 4518
Fax ~ 630/ 573-5374

Total Control Panel Login

To: hollys@suburbanlabs.com

Remove this sender from my allow list

From: bjakupi@butler53.com

You received this message because the sender is on your allow list.

Page 7 of 9

Results addressed to: Butler School Dist. 53

Bob Jakupi 2801 York Rd. Oak Brook, Illinois 60523 6305732887 QTY Item

15 Lead in Schools Regular (school)

Notes:

Page 8 of 9

#	Where? (ie. kitchen sink)		Whe	1?
19 4	outside em 106 Water fauntaja	(draw)		
²⁰ c		(flush)	<u> </u>	AM PM
21	200 Hall Water Lountain,	(draw)	_	
22 5	200 Hall Water Launtain	(flush)	<u> 8:20</u>	AM PM
23 .	Teachere Counge Water Cooker	(draw)	40	_
24	Leucher Course Water Cooler	(flush)	<u>8:25</u>	AM PM
25	\mathcal{J}	(draw)		
26		(flush)		_ AM PM
27		(draw)		
28		(flush)		_ AM PM
29		(draw)		
30		(flush)	*	_ AM PM
31		(draw)		
32		(flush)	*	_ AM PM
33		(draw)		
34		(flush)	:	_ AM PM
35		(draw)		
36		(flush)	:	_ AM PM
How	are you returning the samples? FedEx UPS USP	S Dropoff Other	er:	
>> 1	▶▶▶▶▶▶▶▶▶▶₽LEASE RETURN LAB FORM W	ITH SAMPLES◀	4444444	4444444
LAB	ONLY Personnel:		WO <u> 90 9 (€2</u> PO 2859	
		0	L	AB FORM 2 OF 2

Results addressed to: Butler School Dist. 53 Bob Jakupi 2801 York Rd. Oak Brook, Illinois 60523

6305732887

Notes:

QTY Item

Lead in Schools Regular (school)

■ When was the water last used?

₩ Who is collecting the samples?

Bob Jokespi

09109119 11:30 AM PM

Date of sample collection:

09/10/19

# Where? (ie. kitchen sink)		When?
1 Nuas Rm. SINK	(draw)	_
2 Nurses Rm. SINK	(flush)	7 :30 (AM) PM
3 outside 300 Water fauntain	(draw)	_
4 autido 300 Water facentain	(flush)	/:_35 (AM) PM
5 outside 305 Water faux faire	(draw)	
6 autside 305 Water facentain	(flush)	<u>/</u> : <u>40</u> , (M) PM
7 autoide 308 Water fountain	(draw)	1
8 autide 308 Water fountain	(flush)	7: 45 (AM) PM
9 Main Coston Water Launtain	(draw)	_
10 Mais Cobby Water Lountain	(flush)	7:50AM PM
11 Kitchen Hand sink	(draw)	
12 Kitchen Itand sink	(flush)	L: 55 AM PM
13 emior Hand sink	(draw)	
14 RM WOZ Handsink	(flush)	3 : <u>00 (</u> AM) PM
15 100 Wing Girls Bouthwoon Water found	(draw)	m
16 100 Wine Carila Bethrong Water Lountain	(flush)	S: <u>OS</u> (AM) PM
17 Loom 103 Hand sinh	(draw)	
18 Room 103 Handsink	(flush) (3 : 10 (AM) PM

ı	Þ١	Þ١	Þ١	>	▶	▶	b	Þ	- D	- 1	١	▶	Þ	·P	1	F	Δ.	SF	: F	₹F	т	H	R	N	1	Δ	R	ì F	=()I	71	VI	W	/1"	T١	1 !	S	۱ ۵	Мľ	וכ	F	S٠	4	4	4	4	4	4	4	4		14	14	14	(4	14	14	14	1
	- 1	- 1	_												_	_	_			'		$\mathbf{\mathcal{V}}$			_	.,		, ,	•	_		•	•	,.			•	٦,		_	_	•	┫.	┓.	┫.	┓.	٦.	٦.	٦.	•	 _	•	•	•	4 7	•	•	•	4

LAB ONLY	Personnel:	wo 1909 628
LABONLI	/	PO 2859

9.10.19 9:55 JAS

LAB & ORM 1 OF 2